



LEGEND

LDP Area

Lots Subject to LDP

Vehicle Access Restriction

Uniform Fencing

Mandatory Garage Location

Primary Street Orientation

Upper Floor

Ground Floor

Specialist

Package A

Package B

Package C

LOCAL DEVELOPMENT PLAN PROVISIONS

The provisions listed below and accompanying plan relate to the WAPC subdivision approval reference 200665.

The development standards contained in the Local Development Plan (LDP) apply in addition to those development requirements of the *City of Wanneroo District Planning Scheme No. 2 (DPS 2)*, any relevant planning policy effective under DPS 2 (including *Local Planning Policy 4.19 - Medium Density Housing Standards (LPP 4.19)*) and the *Residential Design Codes (R-Codes)* as applicable.

Where a development standard is specifically stipulated within this LDP, that standard prevails over the requirements of the R-MD Codes, the R-Codes and any other requirements of DPS 2. The requirements of the R-MD Codes shall generally prevail, with the R-Codes and DPS 2 to be satisfied in all other matters.

Single Houses that are entirely compliant with the provisions of this LDP, the City's *Local Planning Policy 4.19 Medium-Density Housing Standards*, and any relevant deemed-to-comply provisions of the R-Codes, do not require development approval.

The LDP provisions apply to lots identified within the Local Development Plan/s. The density code for each lot is as per the prevailing R-Codes Plan.

Quiet House Design

- As defined in the *Transportation Noise Assessment* for Lot 9502 Toreopango Avenue, Yanchep (WAPC 200665), the Quiet House design packages referenced on the LDP Map and the appended tables apply.
- Lots annotated as 'Specialist' for Quiet House design require assessment by a suitably-qualified acoustic consultant as part of the house design process to inform the Quiet House construction standards that will need to be implemented as part of the construction process. This is to ensure that acoustic management for the resultant dwelling/s is compliant with State Planning Policy No. 5.4: Road and Rail Noise.
- Modifications to the Quiet House construction standards may be approved by the City of Wanneroo where it can be demonstrated that the proposed development will be provided with an acceptable level of acoustic amenity. Any such modifications shall be specified in a Transportation Noise Assessment undertaken by a suitably-qualified consultant, to the satisfaction of the City.

Vehicle Access and Garage Locations

- Vehicle access for all corner lots within the LDP area, excluding Lot 159, 513 and laneway lots, is permitted via either the primary street or secondary street.
- Garage locations shall be in accordance with the locations identified on this LDP where applicable.

Primary Street Orientation / Street Interface

- Primary street orientation shall be provided as identified on this LDP.

This Local Development Plan has been approved by the City of Wanneroo under Clause 52(1)(a) of the Deemed Provisions of District Scheme No. 2.

*N. de Vecchis* 2 October 2025  
Manager Approval Services Date

Local Development Plan Expiry Date: 2 October 2035



## Quiet House Package A

56-58 dB  $L_{Aeq}(\text{Day})$  & 51-53 dB  $L_{Aeq}(\text{Night})$

Element	Orientation	Room	
		Bedroom	Indoor Living and Work Areas
External Windows	Facing	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 28</math>): <ul style="list-style-type: none"> <li>Sliding or double hung with minimum 10mm single or 6mm-12mm-10mm double insulated glazing;</li> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 31</math>): <ul style="list-style-type: none"> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 25</math>): <ul style="list-style-type: none"> <li>Sliding or double hung with minimum 6mm single or 6mm-12mm-6mm double insulated glazing;</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 28</math>);</li> <li>Up to 80% floor area (<math>R_w + C_{tr} \geq 31</math>).</li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	No specific requirements	
External Doors	Facing	<ul style="list-style-type: none"> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 28</math> rated door and frame including seals and 6mm glass.</li> </ul>	<ul style="list-style-type: none"> <li>Doors to achieve <math>R_w + C_{tr} \geq 25</math>: <ul style="list-style-type: none"> <li>35mm Solid timber core hinged door and frame system certified to <math>R_w 28</math> including seals;</li> <li>Glazed sliding door with 10mm glass and weather seals.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less.	
	Opposite	No specific requirements	
External Walls	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 45</math>: <ul style="list-style-type: none"> <li>Two leaves of 90mm thick clay brick masonry with minimum 20mm cavity; or</li> <li>Single leaf of 150mm brick masonry with 13mm cement render on each face; or</li> <li>One row of 92mm studs at 600mm centres with: <ul style="list-style-type: none"> <li>Resilient steel channels fixed to the outside of the studs; and</li> <li>9.5mm hardboard or fibre cement sheeting or 11mm fibre cement weatherboards fixed to the outside;</li> <li>75mm thick mineral wool insulation with a density of at least 11kg/m<sup>3</sup>; and</li> <li>2 x 16mm fire-rated plasterboard to inside.</li> </ul> </li> </ul> </li> </ul>	
Roofs and Ceilings	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 35</math>;</li> <li>Concrete or terracotta tile or metal sheet roof with sarking and at least 10mm plasterboard.</li> </ul>	
Outdoor Living Areas		At least one outdoor living area located on the opposite side of the building from the transport corridor and/or at least one ground level outdoor living area screened using a solid continuous fence or other structure of minimum 2 metres height above ground level.	

## Quiet House Package B

59-62 dB  $L_{Aeq}(\text{Day})$  & 54-57 dB  $L_{Aeq}(\text{Night})$

Element	Orientation	Room	
		Bedroom	Indoor Living and Work Areas
External Windows	Facing	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 31</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 6mm glass or 6mm-12mm-6mm double insulated glazing.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 34</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 10mm glass or 6mm-12mm-10mm double insulated glazing.</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 28</math>): <ul style="list-style-type: none"> <li>Sliding or double hung with 6mm-12mm-10mm double insulated glazing;</li> <li>Sealed awning or casement windows with minimum 6mm glass.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 31</math>);</li> <li>Up to 80% floor area (<math>R_w + C_{tr} \geq 34</math>).</li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Doors	Facing	<ul style="list-style-type: none"> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 31</math> rated door and frame including seals and 10mm glass.</li> </ul>	<ul style="list-style-type: none"> <li>Doors to achieve <math>R_w + C_{tr} \geq 28</math>: <ul style="list-style-type: none"> <li>40mm Solid timber core hinged door and frame system certified to <math>R_w 32</math> including seals;</li> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 28</math> rated door and frame including seals and 6mm glass.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Walls	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 50</math>: <ul style="list-style-type: none"> <li>Two leaves of 90mm thick clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester (24kg/m<sup>3</sup>). Resilient ties used where required to connect leaves.</li> <li>Two leaves of 110mm clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester insulation (24kg/m<sup>3</sup>).</li> <li>Single leaf of 220mm brick masonry with 13mm cement render on each face.</li> <li>150mm thick unlined concrete panel or 200mm thick concrete panel with one layer of 13mm plasterboard or 13mm cement render on each face.</li> <li>Single leaf of 90mm clay brick masonry with: <ul style="list-style-type: none"> <li>A row of 70mm x 35mm timber studs or 64mm steel studs at 600mm centres;</li> <li>A cavity of 25mm between leaves;</li> <li>50mm glasswool or polyester insulation (11kg/m<sup>3</sup>) between studs; and</li> <li>One layer of 10mm plasterboard fixed to the inside face.</li> </ul> </li> </ul> </li> </ul>	
Roofs and Ceilings	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 35</math>: <ul style="list-style-type: none"> <li>Concrete or terracotta tile or metal sheet roof with sarking and at least 10mm plasterboard ceiling with R3.0+ fibrous insulation.</li> </ul> </li> </ul>	
Outdoor Living Areas		At least one outdoor living area located on the opposite side of the building from the transport corridor and/or at least one ground level outdoor living area screened using a solid continuous fence or other structure of minimum 2.4 metres height above ground level.	



## Quiet House Package C

63-66 dB  $L_{Aeq}(\text{Day})$  & 58-61 dB  $L_{Aeq}(\text{Night})$

Element	Orientation	Room	
		Bedroom	Indoor Living and Work Areas
External Windows	Facing	<ul style="list-style-type: none"> <li>Up to 20% floor area (<math>R_w + C_{tr} \geq 31</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 6mm glass or 6mm-12mm-6mm double insulated glazing.</li> </ul> </li> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 34</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 10mm glass or 6mm-12mm-10mm double insulated glazing.</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>Up to 40% floor area (<math>R_w + C_{tr} \geq 31</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 6mm glass or 6mm-12mm-6mm double insulated glazing.</li> </ul> </li> <li>Up to 60% floor area (<math>R_w + C_{tr} \geq 34</math>): <ul style="list-style-type: none"> <li>Fixed sash, awning or casement with minimum 10mm glass or 6mm-12mm-10mm double insulated glazing.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Doors	Facing	<ul style="list-style-type: none"> <li>Not recommended.</li> </ul>	<ul style="list-style-type: none"> <li>Doors to achieve <math>R_w + C_{tr} \geq 30</math>: <ul style="list-style-type: none"> <li>Fully glazed hinged door with certified <math>R_w + C_{tr} \geq 31</math> rated door and frame including seals and 10mm glass;</li> <li>40mm Solid timber core side hinged door, frame and seal system certified to <math>R_w 32</math> including seals. Any glass inserts to be minimum 6mm.</li> </ul> </li> </ul>
	Side On	As above, except $R_w + C_{tr}$ values may be 3 dB less or max % area increased by 20%.	
	Opposite	As above, except $R_w + C_{tr}$ values may be 6 dB less or max % area increased by 20%.	
External Walls	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 50</math>: <ul style="list-style-type: none"> <li>Two leaves of 90mm thick clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester insulation (<math>24\text{kg/m}^3</math>). Resilient ties used where required to connect leaves.</li> <li>Two leaves of 110mm clay brick masonry with minimum 50mm cavity between leaves and 25mm glasswool or polyester insulation (<math>24\text{kg/m}^3</math>).</li> <li>Single leaf of 220mm brick masonry with 13mm cement render on each face.</li> <li>150mm thick unlined concrete panel or 200mm thick concrete panel with one layer of 13mm plasterboard or 13mm cement render on each face.</li> <li>Single leaf of 90mm clay brick masonry with: <ul style="list-style-type: none"> <li>A row of 70mm x 35mm timber studs or 64mm steel studs at 600mm centres;</li> <li>A cavity of 25mm between leaves;</li> <li>50mm glasswool or polyester insulation (<math>11\text{kg/m}^3</math>) between studs; and</li> <li>One layer of 10mm plasterboard fixed to the inside face.</li> </ul> </li> </ul> </li> </ul>	
Roofs and Ceilings	All	<ul style="list-style-type: none"> <li><math>R_w + C_{tr} \geq 40</math>: <ul style="list-style-type: none"> <li>Concrete or terracotta tile roof with sarking, or metal sheet roof with foil backed R2.0+ fibrous insulation between steel sheeting and roof battens;</li> <li>R3.0+ insulation batts above ceiling;</li> <li>2 x 10mm plasterboard ceiling or 1 x 13mm sound-rated plasterboard affixed using steel furring channel to ceiling rafters.</li> </ul> </li> </ul>	
Outdoor Living Areas		At least one outdoor living area located on the opposite side of the building from the transport corridor and/or at least one ground level outdoor living area screened using a solid continuous fence or other structure of minimum 2.4 metres height above ground level.	